
**Gaseous fire-extinguishing systems —
Physical properties and system
design —**

**Part 9:
HFC 227ea extinguishant**

*Systèmes d'extinction d'incendie utilisant des agents gazeux —
Propriétés physiques et conception des systèmes —*

Partie 9: Agent extincteur HFC 227ea



COPYRIGHT PROTECTED DOCUMENT

© ISO 2016, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Contents

Page

Foreword	iv
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Characteristics and uses	1
4.1 General	1
4.2 Use of HFC 227ea systems	2
5 Safety of personnel	5
6 System design	5
6.1 Fill density	5
6.2 Superpressurization	6
6.3 Extinguishant quantity	6
7 Environmental properties	9

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html.

The committee responsible for this document is ISO/TC 21, *Equipment for fire protection and fire fighting*, Subcommittee SC 8, *Gaseous media and fire fighting systems using gas*.

This third edition cancels and replaces the second edition (ISO 14520-9:2006), which has been technically revised with the following changes:

- added reference to the 50 bar system in Scope;
- added reference to the 50 bar system in [6.1](#);
- added reference to the 50 bar system in [6.2](#);
- added [Table 10](#) for 50 bar storage container characteristics data;
- added [Figure 3](#), pressure vs temperature chart for 50 bar system;
- added [Clause 7](#).

A list of all parts in the ISO 14520 series can be found on the ISO website.

Gaseous fire-extinguishing systems — Physical properties and system design —

Part 9: HFC 227ea extinguishant

1 Scope

This document contains specific requirements for gaseous fire-extinguishing systems, with respect to the HFC 227ea extinguishant. It includes details of physical properties, specification, usage and safety aspects.

This document covers systems operating at nominal pressures of 25 bar, 42 bar and 50 bar with nitrogen propellant. This does not preclude the use of other systems.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 14520-1:2015, *Gaseous fire-extinguishing systems — Physical properties and system design — Part 1: General requirements*.

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 14520-1 apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

4 Characteristics and uses

4.1 General

Extinguishant HFC 227ea shall comply with the specification shown in [Table 1](#).

HFC 227ea is a colourless, almost odourless, electrically non-conductive gas, with a density approximately six times that of air.

The physical properties are shown in [Table 2](#).

HFC 227ea extinguishes fires mainly by physical means, but also by some chemical means.

Table 1 — Specification for HFC 227ea

Property	Requirement
Purity	99,6 % by mass, min.
Acidity	3×10^{-6} by mass, max.
Water content	10×10^{-6} by mass, max.
Non-volatile residue	0,01 % by mass, max.
Suspended matter or sediment	None visible

Table 2 — Physical properties of HFC 227ea

Property	Units	Value
Molecular mass	—	170
Boiling point at 1,013 bar (absolute)	°C	-16,4
Freezing point	°C	-127
Critical temperature	°C	101,7
Critical pressure	bar abs	29,26
Critical volume	cm ³ /mol	274
Critical density	kg/m ³	573
Vapour pressure 20 °C	bar abs	3,90
Liquid density 20 °C	kg/m ³	1 410
Saturated vapour density 20 °C	kg/m ³	31,035
Specific volume of superheated vapour at 1,013 bar and 20 °C	m ³ /kg	0,137 4
Chemical formula	CF ₃ CHF ₂ CF ₃	
Chemical name	Heptafluoropropane	

4.2 Use of HFC 227ea systems

HFC 227ea total flooding systems may be used for extinguishing fires of all classes within the limits specified in ISO 14520-1:2015, Clause 4.

The extinguishant requirements per volume of protected space are shown in [Table 3](#) for various levels of concentration. These are based on methods shown in ISO 14520-1:2015, 7.6.

The extinguishing concentrations and design concentrations for *n*-heptane and surface class A hazards are shown in [Table 4](#). Concentrations for other fuels are shown in [Table 5](#) and inerting concentrations are shown in [Table 6](#).

Table 3 — HFC 227ea total flooding quantity

Temperature <i>T</i> °C	Specific vapour volume <i>S</i> m ³ /kg	HFC 227ea mass requirements per unit volume of protected space, <i>m/V</i> (kg/m ³)									
		Design concentration (by volume)									
		6 %	7 %	8 %	9 %	10 %	11 %	12 %	13 %	14 %	15 %
-10	0,1215	0,5254	0,6196	0,7158	0,8142	0,9147	1,0174	1,1225	1,2301	1,3401	1,4527
-5	0,1241	0,5142	0,6064	0,7005	0,7967	0,8951	0,9957	1,0985	1,2038	1,3114	1,4216
0	0,1268	0,5034	0,5936	0,6858	0,7800	0,8763	0,9748	1,0755	1,1785	1,2839	1,3918
5	0,1294	0,4932	0,5816	0,6719	0,7642	0,8586	0,9550	1,0537	1,1546	1,2579	1,3636
10	0,1320	0,4834	0,5700	0,6585	0,7490	0,8414	0,9360	1,0327	1,1316	1,2328	1,3364
15	0,1347	0,4740	0,5589	0,6457	0,7344	0,8251	0,9178	1,0126	1,1096	1,2089	1,3105
20	0,1373	0,4650	0,5483	0,6335	0,7205	0,8094	0,9004	0,9934	1,0886	1,1859	1,2856
25	0,1399	0,4564	0,5382	0,6217	0,7071	0,7944	0,8837	0,9750	1,0684	1,1640	1,2618
30	0,1425	0,4481	0,5284	0,6104	0,6943	0,7800	0,8676	0,9573	1,0490	1,1428	1,2388
35	0,1450	0,4401	0,5190	0,5996	0,6819	0,7661	0,8522	0,9402	1,0303	1,1224	1,2168
40	0,1476	0,4324	0,5099	0,5891	0,6701	0,7528	0,8374	0,9239	1,0124	1,1029	1,1956
45	0,1502	0,4250	0,5012	0,5790	0,6586	0,7399	0,8230	0,9080	0,9950	1,0840	1,1751
50	0,1527	0,4180	0,4929	0,5694	0,6476	0,7276	0,8093	0,8929	0,9784	1,0660	1,1555
55	0,1553	0,4111	0,4847	0,5600	0,6369	0,7156	0,7960	0,8782	0,9623	1,0484	1,1365
60	0,1578	0,4045	0,4770	0,5510	0,6267	0,7041	0,7832	0,8641	0,9469	1,0316	1,1183
65	0,1604	0,3980	0,4694	0,5423	0,6167	0,6929	0,7707	0,8504	0,9318	1,0152	1,1005
70	0,1629	0,3919	0,4621	0,5338	0,6072	0,6821	0,7588	0,8371	0,9173	0,9994	1,0834
75	0,1654	0,3859	0,4550	0,5257	0,5979	0,6717	0,7471	0,8243	0,9033	0,9841	1,0668
80	0,1679	0,3801	0,4482	0,5178	0,5890	0,6617	0,7360	0,8120	0,8898	0,9694	1,0509
85	0,1704	0,3745	0,4416	0,5102	0,5803	0,6519	0,7251	0,8000	0,8767	0,9551	1,0354
90	0,1730	0,3690	0,4351	0,5027	0,5717	0,6423	0,7145	0,7883	0,8638	0,9411	1,0202
95	0,1755	0,3638	0,4290	0,4956	0,5636	0,6332	0,7044	0,7771	0,8516	0,9277	1,0057
100	0,1780	0,3587	0,4229	0,4886	0,5557	0,6243	0,6945	0,7662	0,8396	0,9147	0,9916

NOTE This information refers only to the product HFC-227ea and does not represent any other products containing 1,1,1,2,3,3,3-heptafluoropropane as a component.

Symbols:

m/V is the agent mass requirements (kg/m³); i.e. mass, *m*, in kilograms of agent required per cubic metre of protected volume, *V*, to produce the indicated concentration at the temperature specified;

V is the net volume of hazard (m³); i.e. the enclosed volume minus the fixed structures impervious to extinguishant

$$m = \left(\frac{c}{100 - c} \right) \frac{V}{S}$$

T is the temperature (°C); i.e. the design temperature in the hazard area;

S is the specific volume (m³/kg); the specific volume of superheated HFC 227ea vapour at a pressure of 1,013 bar may be approximated by the formula

$$S = k_1 + k_2 T$$

where

$$k_1 = 0,1269$$

$$k_2 = 0,000513$$

c is the concentration (%); i.e. the volumetric concentration of HFC 227ea in air at the temperature indicated and a pressure of 1,013 bar absolute.

Table 4 — HFC 227ea reference extinguishing and design concentrations

Fuel	Extinguishment % by volume	Minimum design % by volume
Class B		
Heptane (cup burner)	6,7	9,0
Heptane (room test)	6,9	
Surface Class A		
Wood Crib	4,9	7,9
PMMA	6,1	
PP	6,1	
ABS	6,1	
Higher Hazard Class A	See Note 4	8,5
NOTE 1 The extinguishment values for the Class B and the Surface Class A fuels are determined by testing in accordance with ISO 14520-1:2015, Annexes B and C.		
NOTE 2 The minimum design concentration for the Class B fuel is the higher value of the heptane cup burner or room test heptane extinguishment concentration multiplied by 1,3.		
NOTE 3 The minimum design concentration for Surface Class A fuel is the highest value of the wood crib, PMMA, PP or ABS extinguishment concentrations multiplied by 1,3. In the absence of any of the four extinguishment values, the minimum design concentration for Surface Class A is that of Higher Hazard Class A.		
NOTE 4 The minimum design concentration for Higher Hazard Class A fuels is the higher of the Surface Class A or 95% of the Class B minimum design concentration.		
NOTE 5 See ISO 14520-1:2015, 7.5.1.3 for guidance on Class A fuels.		

In [Table 4](#), the extinguishing and design concentrations for room-scale test fires are for informational purposes only. Lower and higher extinguishing concentrations than those shown for room-scale test fires may be achieved and allowed when validated by test reports from internationally recognized laboratories.

Table 5 — HFC 227ea extinguishing and design concentrations for other fuels

Fuel	Extinguishment % by volume	Minimum design % by volume
Acetone	6,7	8,7
Ethanol	8,4	10,9
Ethyl acetate	6,7	8,7
Ethylene glycol	7,8	10,1
Kerosene	6,1	7,9
Methanol	9,5	12,4
Propane	7,4	9,6
Toluene	4,9	6,4
NOTE Extinguishing concentrations for all Class B fuels listed were derived in accordance with ISO 14520-1:2015, Annex B.		
Minimum design values have been increased to the minimum design concentration established for heptane in accordance with ISO 14520-1:2015, 7.5.1.		

Table 6 — HFC 227ea inerting and design concentrations

Fuel	Inertion % by volume	Minimum design % by volume
Isobutane	11,3	12,4
1-Chloro-1,1-difluoroethane (HCFC 141b)	6,7	8,7
1,1-Difluoroethane (HFC 152a)	8,6	9,5
Difluoromethane (HFC 32)	6,7	8,7
Ethylene oxide	13,6	15,0
Methane	8,0	8,8
Pentane	11,6	12,8
Propane	11,6	12,8

NOTE Inerting concentrations were derived in accordance with the requirements of ISO 14520-1:2015, Annex D and 7.5.2.

5 Safety of personnel

Any hazard to personnel created by the discharge of HFC 227ea shall be considered in the design of the system.

Potential hazards can arise from the following:

- a) the extinguishant itself;
- b) the combustion products of the fire;
- c) breakdown products of the extinguishant resulting from exposure to fire.

For minimum safety requirements, see ISO 14520-1:2015, Clause 5.

Toxicological information for HFC 227ea is shown in [Table 7](#).

Table 7 — Toxicological information for HFC 227ea

Property	Value % by volume
ALC	>80 at 20 % O ₂
No observed adverse effect level (NOAEL)	9,0
Lowest observed adverse effect level (LOAEL)	10,5

NOTE ALC is the approximate lethal concentration for a rat population during a 4-h exposure.

6 System design

6.1 Fill density

The fill density of the container shall not exceed the values given in [Table 8](#), [Table 9](#), and [Table 10](#) for 25 bar, 42 bar or 50 bar systems.

Exceeding the maximum fill density may result in the container becoming “liquid full”, with the effect that an extremely high rise in pressure occurs with small increases in temperature, which could adversely affect the integrity of the container assembly.

The relationships between pressure and temperature are shown in [Figure 1](#) and [Figure 2](#) for various levels of fill density.

Table 8 — 25 bar storage container characteristics for HFC 227ea

Property	Unit	Value
Maximum fill density	kg/m ³	1 150
Maximum container working pressure at 50 °C	bar	34
Superpressurization at 21 °C	bar	25
NOTE Reference should be made to Figure 1 for further data on pressure/temperature relationships.		

Table 9 — 42 bar storage container characteristics for HFC 227ea

Property	Unit	Value
Maximum fill density	kg/m ³	1 150
Maximum container working pressure at 50 °C	bar	62
Superpressurization at 21 °C	bar	42
NOTE Reference should be made to Figure 2 for further data on pressure/temperature relationships.		

Table 10 — 50 bar storage container characteristics for HFC 227ea

Property	Unit	Value
Maximum fill density	kg/m ³	1 050
Maximum container working pressure at 50 °C	bar	59
Superpressurization at 21 °C	bar	50
NOTE Reference should be made to Figure 3 for further data on pressure/temperature relationships.		

6.2 Superpressurization


Containers shall be pressurized with nitrogen with a moisture content of not more than 60×10^{-6} by mass to an equilibrium pressure of 25 bar $^{+5}_0$ %, 42 bar $^{+5}_0$ % or 50 bar $^{+5}_0$ % for the respective system, at a temperature of 21 °C.

6.3 Extinguishant quantity

The quantity of extinguishant shall be the minimum required to achieve the design concentration within the hazard volume at the minimum expected temperature, determined using [Table 3](#) and the method specified in ISO 14520-1:2015, 7.6.

The design concentrations shall be that specified for relevant hazards shown in [Table 4](#). This includes at least a 1,3 safety factor on the extinguishing concentration.

Consideration should be given to increasing this for particular hazards, and seeking advice from the relevant authority.




Key

X temperature, °C

Y pressure, bar

Figure 1 — Temperature/pressure graph for HFC 227ea superpressurized with nitrogen to 25 bar at 21 °C

Values of density in kilograms per cubic metre




Key

X temperature, °C

Y pressure, bar

Figure 2 — Temperature/pressure graph for HFC 227ea pressurized with nitrogen to 42 bar at 21 °C

**Key**

X temperature, °C

Y pressure, bar

Figure 3 — Temperature/pressure graph for HFC 227ea superpressurized with nitrogen to 50 bar at 21 °C

7 Environmental properties

For information purposes, environmental properties of HFC 227ea extinguishant are provided:

GWP (100 years)	3220
-----------------	------

ODP	0 ¹⁾
-----	-----------------

NOTE 1 See ISO 14520-1:2015, 4.2.1 for a discussion of GWP values and their relation to the impact of a gas on climate change/global warming.

NOTE 2 Environmental properties derived from the following:

- 2005 IPCC/TEAP Special Report Safeguarding the Ozone Layer and the Global Climate System: Issues Related to Hydrofluorocarbons and Perfluorocarbons;
- 2007 Fourth Assessment Report of the Intergovernmental Panel on Climate Change;
- U.S. EPA.

1) Extinguishant HFC 227ea has zero ODP because it contains no chlorine, bromine, or iodine, the primary kinetically active species for ozone depletion.

