

Serial number	Distribution box at test point	Current A	Current B	Current C	Current N	Total distortion rate of harmonic current	Current N/Phase line current	Third harmonic content and effective value
1	TYZX-AL5	267	265	269	439	76.7%	1.64 times	68.6% (125.8A)
2	TYZX-AL6	170	170	179	295	77.9%	1.69 times	71.8%(83.4A)
3	TYZX-AL7	313	349	349	537	70.8%	1.59 times	64.4% (149.4A)
4	TYZX-AL8	173	186	169	299	90.2%	1.70 times	77.6% (105.4A)
5	TYZX-AL9	102	106	104	170	90.1%	1.63 times	73.1%(56.5A)