

ПІДТВЕРДЖУВАЛЬНЕ ПОВІДОМЛЕННЯ

Державне підприємство
«Український науково-дослідний і навчальний центр
проблем стандартизації, сертифікації та якості»
(ДП «УкрНДНЦ»)

Наказ від 12.04.2021 № 137

ISO 21927-5:2018

Smoke and heat control systems — Part 5: Powered smoke exhaust systems — Requirements and design

прийнято як національний стандарт
методом «підтвердження» за позначенням

ДСТУ ISO 21927-5:2021
(ISO 21927-5:2018, IDT)

**Системи протидимового захисту. Частина 5. Системи примусового видалення диму. Вимоги,
проектування та монтування**

З наданням чинності від 2021–05–01

Відповідає офіційному тексту

**З питань придбання
офіційного видання звертайтеся до
національного органу стандартизації
(ДП «УкрНДНЦ» <http://uas.org.ua>)**

Smoke and heat control systems —
Part 5:
Powered smoke exhaust systems —
Requirements and design

Installations pour l'extraction de fumée et de chaleur —

Partie 5: Systèmes d'extraction de fumée mécaniques — Exigences et planification



COPYRIGHT PROTECTED DOCUMENT

© ISO 2018, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Design principles	2
4.1 General	2
4.2 Height of space	4
4.3 Target height of the clear layer, d , in a smoke reservoir, A_R	4
4.4 Area of smoke reservoir, A_R	4
4.5 Air supply	4
4.5.1 General	4
4.5.2 Natural air replacement	5
4.5.3 Powered air replacement	5
4.6 Duration of fire growth to be assumed in the design	5
4.7 Design group	5
5 Calculating the volume flow of the smoke gases to be exhausted	6
5.1 Basis of the calculation	6
5.2 Using the tables	6
6 Component temperature classes	8
7 Rules for installation	9
8 Energy supply for powered smoke exhaust ventilators	13
9 Controlling powered smoke exhaust ventilators	13
10 Marking	13
Bibliography	14

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 21, *Equipment for fire protection and fire fighting*, Subcommittee SC 11, *Smoke and heat control systems and components*.

A list of all parts in the ISO 21927 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

Smoke and heat control systems (SHCS) create and maintain smoke free areas in construction works by controlling smoke flow, and thus improving the conditions for the safe escape and/or rescue of people and animals and the protection of property, and permit the fire to be fought while still in its early stages. The use of smoke and heat exhaust ventilation systems (SHEVS) to create smoke-free areas beneath a buoyant smoke layer has become widespread. Their value in assisting in the evacuation of people from construction works, reducing fire damage and financial loss by preventing smoke logging, facilitating firefighting, reducing roof temperatures and retarding the lateral spread of fire is firmly established. For these benefits to be obtained, it is essential that smoke and heat exhaust ventilators operate fully and reliably whenever called upon to do so during their installed life. A heat and smoke exhaust ventilation system is a scheme of safety equipment intended to play a positive role in a fire emergency.

Components for any smoke and heat control system are installed as part of a properly designed system.

Smoke and heat control systems help to:

- keep escape and access routes free from smoke;
- facilitate firefighting operations;
- delay and/or prevent flashover and thus full development of a fire;
- protect equipment and furnishings;
- reduce thermal effects on structural components during a fire;
- reduce damage due to thermal decomposition products and hot gases.

Pressure differential systems are used either to positively pressurize spaces separated from the fire or to depressurize the space containing the fire in order to limit or prevent the flow of smoke and heat into adjacent spaces. A typical use would be to pressurize an escape stair well in order to protect vertical means of escape.

Depending on the design of the system, natural or powered smoke and heat ventilators can be used in a smoke and heat control system.

Control equipment is needed to control all components in a SHCS, such as:

- natural ventilators;
- powered ventilators;
- smoke barriers;
- smoke dampers;
- air inlets;
- duct sections;
- dampers.

SHCS control equipment can also provide control for day-to-day ventilation and signals to other fire safety equipment under fire conditions.

SHCS control equipment can be for extra-low-voltage or low-voltage electrical systems or pneumatic systems or any combination thereof.

Smoke and heat control systems —

Part 5:

Powered smoke exhaust systems — Requirements and design

1 Scope

This document applies to powered smoke exhaust systems in spaces with a large area and with a ceiling height of minimum 3 m, in which smoke protection is required. It includes tables and calculation methods for the design of clear layers in order to comply, inter alia, with the requirements of various protection objectives.

This document includes information and provisions concerning the requirements for powered smoke exhaust systems, their design and rules for their installation.

NOTE The requirements for testing the ventilators are dealt with in ISO 21927-3. Other parts of the ISO 21927 series of standards deal with the power supply (ISO 21927-10), control equipment (ISO 21927-9) and smoke control ducts and smoke control dampers (ISO 21927-7 and ISO 21927-8 respectively).

Design, as specified in this document, does not apply to:

- spaces with fixed gas extinguishing systems;
- storage facilities for hazardous materials;
- spaces in which there is a risk of explosions;
- corridors;
- stairwells.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 21927-3, Smoke and heat control systems — Part 3: Specification for powered smoke and heat exhaust ventilators

ISO 21927-8, Smoke and heat control systems — Part 8: Smoke control dampers

ISO 21927-9, Smoke and heat control systems — Part 9: Specification for control equipment

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 21927-3 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.1

roof-mounted ventilator

smoke exhaust ventilator designed to be mounted on a roof above a smoke reservoir and having exterior weather protection

3.2

wall-mounted ventilator

smoke exhaust ventilator designed to be mounted in the upper part of an external wall

3.3

centrally installed ventilator

smoke exhaust ventilator to which *smoke control ducts* (3.7) from several smoke reservoirs can be connected

3.5

area of smoke reservoir

A_a

area within a large space enclosed or bounded by smoke barriers or wall elements

3.6

design group

auxiliary design value that is used in the design of powered smoke exhaust systems and takes account of the assumed duration of fire growth and the fire propagation rate

3.7

smoke control duct

duct through which smoke and heat are exhausted

3.8

single compartment smoke control damper

smoke control damper that is designed for use in a single smoke reservoir and can be connected to single compartment *smoke control ducts* (3.7)

3.9


multi-compartment smoke control damper

fire-resistant smoke control damper designed for use in or on *smoke control ducts* (3.7) connecting several smoke reservoirs, or in separating structural elements

4 Design principles

4.1 General

The design of powered smoke exhaust systems (see example in [Figure 1](#)) depends, inter alia, on the heat release rate, the theoretical fire area of a building or the resulting design group, the target height of the clear layer and the height of the space. Possible locations and designs of smoke exhaust ventilators are described in [ISO 21927-3](#).



Key

- 1 possible fire compartment
- 2 smoke layer in smoke reservoir
- 3 air inlet
- 4 smoke barrier (ISO 21927-1)
- 5 smoke exhaust ventilator (ISO 21927-3)
- 6 single compartment smoke control damper (ISO 21927-8)
- 7 smoke control duct for which there are no requirements for the duration of fire resistance (ISO 21927-7)
- 8 smoke control duct for which requirements for the duration of fire resistance apply (ISO 21927-7)
- 9 multi-compartment smoke control damper, installed in a wall or floor (ISO 21927-8)
- 10 multi-compartment smoke control damper, installed in a smoke control duct (ISO 21927-8)
- 11 electric cables

Figure 1 — Diagram showing possible powered smoke exhaust systems

The values to be used to determine the above parameters are auxiliary design values and they only apply to designs in accordance with this document.

Design is based on the following:

- the powered smoke exhaust system is activated at an early stage, e.g. by an automatic fire alarm system with smoke detectors, or immediately by trained personnel that are in attendance around the clock;
- the mean fire propagation rate for an assumed duration of fire growth is around 10 min;
- there is a sufficiently large and evenly distributed air supply through inlets close to floor level; the air supply needs to be effective from the time the powered smoke exhaust system is switched on to avoid turbulence in the smoke (flow rate not greater than 1 m/s at the point at which the replacement air enters the smoke reservoir; this can be achieved by using deflectors, for example);
- large spaces are divided into smoke reservoirs by means of smoke barriers;
- the fires are solid materials fires;
- the fire area does not exceed 80 m² up to the time at which extinguishing measures commence;

- the smoke layer temperatures are below flash-over level.

4.2 Height of space

The height, h , of the space to be protected (as shown in Figure 2), shall be the distance from the floor to the lower surface of the roof/floor in the case of horizontal roofs/floors. For pitched roofs or sloping floors, it shall be the mean distance from the floor to the lower surface of the roof/floor. Floors with smoke outlets are not regarded as floors in this context.

In the case of sawtooth roofs, the space height to be used for design purposes is the mean height of the extraction point of the powered smoke exhaust system above floor level.

4.3 Target height of the clear layer, d , in a smoke reservoir, A_R

The clear layer, d , is defined as the distance between the surface of the floor assumed for design purposes and the lower surface of the smoke layer.

Clear layers enable:

- the occupants of a building to escape to safety,
- the emergency services to rescue people, animals and property,
- fires to be fought effectively, and
- damage due to fire gases and products of thermal decomposition to be reduced.

The target height of the clear layer d (see Figure 2) should be not less than 2,50 m.

Design should be based on higher values of d if so required by the purpose for which the space is to be used (e.g. spaces containing objects sensitive to smoke or flammable warehouse stock). The distance between the objects to be protected and the smoke layer should not be less than 0,5 m.

For clear layers with a height $d \leq 4$ m, the height of the smoke barrier shall protrude at least 0,5 m into the clear layer. For clear layers with a height $d > 4$ m the smoke barrier shall at least equal to the height of the smoke layer, z , but not less than 1,0 m in all cases.

4.4 Area of smoke reservoir, A_R

To enable powered smoke exhaust systems to be designed according to this document, spaces shall either have a maximum area of 1 600 m² or be divided into smoke reservoirs with a maximum area, A_R , of 1 600 m² by means of smoke barriers. The maximum distance between smoke barriers or between wall and smoke barrier shall not exceed 60 m. Any further subdivisions (e.g. closed joists) within the smoke reservoir will not affect the design.

NOTE Smoke reservoirs are created by placing separating elements around the perimeter of a space or, at the minimum, by placing continuous smoke barriers along the open inner sides of a space. A "space" is defined as an area enclosed by separating elements on all sides.

4.5 Air supply

4.5.1 General

A sufficient replacement air supply close to floor level shall be available immediately (e.g. initiated automatically, by the works fire service or as a result of operational or organizational measures) after activation of the powered smoke exhaust system.

The distance between the upper edge of the replacement air inflow and the bottom of the layer of smoke gases shall be not less than 1 m. The distance may be reduced to 0,5 m in the vicinity of replacement air inlets with widths not greater than 1,25 m.

In the case of replacement air inflows resulting in an upward air flow (e.g. those with protective gratings facing upwards), the distance between the upper edge of the replacement air inlet and the bottom of the layer of smoke gases should be not less than 1,5 m.

The air supply can be replenished via openings in the external walls, with the replacement air either being allowed to flow freely into the building, or being conveyed by fans. Powered smoke exhaust systems may operate with a combination of powered and a natural air replacement.

The air replacement rate should not exceed 1 m/s at the point at which the air enters the smoke reservoir.

The air velocity in the replacement air inlet may be greater if appropriate measures (e.g. baffles, deflectors, redirection of air flow at the air inlets) ensure that the horizontal air replacement rate is reduced to 1 m/s at the point at which air enters the smoke reservoir.

4.5.2 Natural air replacement

The following are considered as air inlets:

- separate supply air devices;
- doors or windows provided they are labelled as “air inlets for powered smoke exhaust systems” on the inside and outside and can be opened from outside without being destroyed in the process (e.g. window panes shall not need to be smashed or walls or doors broken down).

4.5.3 Powered air replacement

For the purposes of this document, the volume flow of the replacement air shall be assumed to be equivalent to that of the smoke gases to be exhausted in the case of powered air replacement.

The powered air replacement should be activated either shortly before or at the same time as the powered smoke exhaust system in order to prevent negative pressures occurring in the fire compartment. An automatic control system is therefore preferable.

4.6 Duration of fire growth to be assumed in the design

The duration of fire growth to be assumed for the purposes of this document includes the time that elapses between the outbreak of a fire and the start of firefighting measures. The time elapsing between the outbreak of a fire and the fire alarm being raised is not taken into account as it can either be assumed that the powered smoke exhaust system will be activated at an early stage by a fire detection system or it is ensured that the fire services will be notified promptly and the powered smoke exhaust system is switched on by trained staff that are in attendance around the clock.

An average time of 10 min shall be assumed for the duration of fire growth. In favourable circumstances, such as where there are on-site firefighters, this time may be reduced to 5 min. It shall be increased to 15 min if the circumstances are unfavourable and to 20 min if the circumstances are exceptionally unfavourable.

Powered smoke exhaust systems will need to be combined with an automatic extinguishing system if the assumed duration of fire growth is greater than 20 min and the fire propagation rate exceeds even average values.

4.7 Design group

The design group according to [Table 1](#) corresponds to a theoretical fire area. It is obtained from the assumed duration of fire growth and the fire propagation rate.

The fire propagation rates given in [Table 2](#) are mean values that may be used without further verification. Generally speaking, the values given in line 2 of [Table 1](#) shall be taken as the assumed duration of fire growth. The relevant line and column are highlighted in bold type in [Table 1](#).

The values given in column 2 of [Table 1](#) shall apply if particularly low fire propagation rates (e.g. for combustible materials in non-combustible packaging) can be assumed. The values given in column 4 of [Table 1](#) shall apply in cases where particularly high fire propagation rates can be expected (e.g. storage of materials with a high fire propagation rate).

The design group obtained from [Table 1](#) may be reduced by one level without further verification in cases where an automatic sprinkler system is installed.

The design group obtained from [Table 1](#) shall be increased by one level if the height of stored materials exceeds 1,5 m. The height of the stored materials shall be limited to 1,5 m in cases where design group 5 has already been reached.

Designs for powered smoke exhaust systems intended to maintain a stable clear layer shall be based on a fire scenario of 300 kW/m² in accordance with ISO 21927-4. Components with a resistance to high temperatures shall therefore be used, the choice depending on the volume flows determined. If higher heat release rates are likely to occur, an additional check should be carried out to establish whether the intended protection objective can be achieved with the expected fire scenario.

Higher temperatures than those given in [Table 4](#) can occur in the smoke gases if the volume flows do not reach the values required in accordance with this standard.

Table 1 — Determination of the design group of a powered smoke exhaust system

Column	1	2	3	4
Line	Assumed duration of fire growth (see 4.6) min	Fire propagation rate ^a		
		particularly low	mean ^a	particularly high
1	≤5	1	2	3
2	≤10 ^a	2	3 ^a	4
3	≤15	3	4	5
4	≤20	4	5	—

^a See 4.7 for the meaning of the values highlighted in bold type and given in the boxes with grey shading.

Table 2 — Averaged fire propagation rates

Fire propagation rate	m/min
particularly low	0,15
mean	0,25
particularly high	0,45

5 Calculating the volume flow of the smoke gases to be exhausted

5.1 Basis of the calculation

The values given in the tables are based on a specific heat release rate of 300 kW/m².

5.2 Using the tables

The volume flow of smoke gases to be exhausted by a powered smoke exhaust system shall be obtained from [Table 3](#) for each smoke reservoir.

Conventional designs for smoke exhaust systems shall be based on the values for the volume flow of smoke gases highlighted in bold type.

Table 3 — Volume flow of smoke gases to be exhausted, v_{RS} , in m³/h per smoke reservoir

Line	Height of clear layer m	Design group				
		1	2	3 ^a	4	5
1	2,5	29 000	46 000	75 000	128 000	223 000
2	3	34 000	55 000	88 000	145 000	248 000
3	4	43 000	72 000	115 000	184 000	303 000
4	5	50 000	85 000	143 000	229 000	366 000
5	6	59 000	96 000	165 000	276 000	436 000
6	7	73 000	105 000	183 000	311 000	512 000
7	8	88 000	121 000	197 000	342 000	580 000
8	9	105 000	143 000	206 000	368 000	633 000
9	10	123 000	166 000	231 000	387 000	681 000

^a Volume flow of smoke gases to be assumed for conventional designs.

Table 4 — Mean temperatures of the smoke layer, θ_{RS} , in °C

Line	Height of clear layer m	Design group				
		1	2	3 ^a	4	5
1	2,5	160	210	290	400	560
2	3	130	170	230	310	430
3	4	100	120	150	210	290
4	5	80	100	120	160	210
5	6	70	90	100	120	170
6	7	60	80	90	110	140
7	8	50	70	90	100	120
8	9	50	60	80	90	110
9	10	40	60	70	90	100

^a Volume flow of smoke gases to be assumed for conventional designs.

The temperatures shown in [Table 4](#) are mean temperatures in the smoke layer. Higher smoke gas temperatures, θ_R , can occur locally at the point at which the smoke gases enter the smoke layer.

Owing to the test conditions specified in [ISO 21927-3](#), temperature class F200 or higher shall be selected for smoke exhaust ventilators. The smoke exhaust ventilators have been assigned the temperature classes given in [Table 5](#) to ensure that they also function properly at higher local smoke gas temperatures.

Other components shall be selected on the basis of the lowest temperature class for which the smoke exhaust ventilators are tested, as shown in [Table 6](#) (see [Clause 6](#)).

Table 5 — Temperature classes for smoke exhaust ventilators, taking account of local smoke gas temperatures, θ_R , in °C at the point at which the smoke gases enter the smoke layer

Line	Height of clear layer m	Design group				
		1	2	3 ^a	4	5
1	2,5	F300	F600	F600	F842 ^b	— ^c
2	3	F300	F400	F600	F842 ^b	— ^c
3	4	F200	F300	F300	F400	F600
4	5	F200	F200	F300	F300	F600
5	6	F200	F200	F200	F300	F400
6	7	F200	F200	F200	F200	F300
7	8	F200	F200	F200	F200	F300
8	9	F200	F200	F200	F200	F200
9	10	F200	F200	F200	F200	F200

^a Volume flow to be assumed for conventional designs.

^b A flashover can be expected to occur in this case; a clear layer is unlikely.

^c Not covered by the scope of this document.

NOTE To ensure that smoke exhaust ventilators function properly, the required temperature class was determined either from the local temperature of the smoke gases at the point at which they enter the smoke layer or from the mean temperature of the smoke layer at an energy release rate of 600 kW/m² whichever was the higher.

6 Component temperature classes

Smoke exhaust ventilators used to remove smoke shall satisfy the requirements given in [Table 5](#). The resulting temperature classes shall be used as input values when determining the temperature class of the other components in accordance with [Table 6](#).

Table 6 — Assigning temperature classes to meet the requirements for equipment

Line	Smoke exhaust ventilator according to EN 12101-3 or EN 13501-4	Ventilator including elastic connecting elements; location of ventilator			Smoke control duct according to EN 12101-7 or EN 13501-4		Smoke control dampers according to EN 12101-8 or EN 13501-4	
		In fire compartment	Outside fire compartment, within the building	Outside the building	Single compartment	Multi-compartment	Single compartment	Multi-compartment
1	F200	E ₃₀₀ 30* S	EI xx S	E ₃₀₀ 30* S	E ₃₀₀ 30* S	EI xx S	E ₃₀₀ 30* S	EI xx S
2	F300	E ₃₀₀ 30* S	EI xx S	E ₃₀₀ 30* S	E ₃₀₀ 30* S	EI xx S	E ₃₀₀ 30* S	EI xx S
3	F400 (90) F400 (120)	E ₆₀₀ 30* S	EI xx S	E ₆₀₀ 30* S	E ₆₀₀ 30* S	EI xx S	E ₆₀₀ 30* S	EI xx S

xx The minimum fire resistance requirement is specified in building regulations.

* For operating times exceeding 30 min, the duration should be specified in accordance with the fire safety concept or the construction permit.

Single compartment: The construction products may only be used in the compartment from which smoke is to be removed.

Multi-compartment: Applies where the construction products connect discrete fire compartments.

Line	Smoke exhaust ventilator according to EN 12101-3 or EN 13501-4	Ventilator including elastic connecting elements; location of ventilator			Smoke control duct according to EN 12101-7 or EN 13501-4		Smoke control dampers according to EN 12101-8 or EN 13501-4	
		In fire compartment	Outside fire compartment, within the building	Outside the building	Single compartment	Multi-compartment	Single compartment	Multi-compartment
4	F600	E ₆₀₀ 30* S	EI xx S	E ₆₀₀ 30* S	E ₆₀₀ 30* S	EI xx S	E ₆₀₀ 30* S	EI xx S
5	F842	—	EI xx S	—	—	EI xx S	—	EI xx S
xx The minimum fire resistance requirement is specified in building regulations.								
* For operating times exceeding 30 min, the duration should be specified in accordance with the fire safety concept or the construction permit.								
Single compartment: The construction products may only be used in the compartment from which smoke is to be removed.								
Multi-compartment: Applies where the construction products connect discrete fire compartments.								

7 Rules for installation

Ventilators can be installed on roofs or in walls or centrally installed.

A distinction needs to be made between the following types of ventilator:

- individual wall-mounted ventilators that remove smoke from the smoke reservoir via their own extraction point, without a duct;
- individual roof-mounted ventilators that remove smoke from the smoke reservoir via their own extraction point, without a duct;
- individual ventilators installed in smoke reservoirs and connected to a duct to enable smoke to be extracted from the reservoir;
- centrally installed ventilators that are connected to ducts and ensure that smoke is removed from one or several smoke reservoirs via single compartment or multi-compartment smoke control dampers.


Collector ducts fitted with smoke control dampers may be used. Single compartment smoke control ducts shall normally be closed. Multi-compartment smoke control ducts can normally be open or closed, depending on the type of technical system used.

Smoke control ducts shall satisfy the requirements of [ISO 21927-8](#).

Smoke reservoirs shall be connected to the smoke exhaust ventilator via smoke control ducts by opening the relevant smoke control dampers, thus enabling smoke to be removed.

Extraction points in fire ducts and directly acting smoke exhaust ventilators (single ventilators) shall be spaced as evenly as possible in accordance with [Figure 2](#). Wall-mounted ventilators (acting as single ventilators) shall also be spaced as evenly as possible.

The minimum number of extraction points or single ventilators required will depend on the thickness, Δd_s , of the smoke layer below the extraction point and the mean temperature, θ_{RS} , in the smoke layer.



Key

A_{ex}	extraction point	z	height of smoke layer ($h - d$), in m
A_{in}	size of air inlet, in m ²	1	clear layer
d	height of clear layer, in m	2	plume
h	height of space to be protected, in m	3	smoke layer
H_{SB}	height of smoke barrier, in m	B	clear width of extraction point, in m
$\Delta d_{\text{S}}^{\text{a}}$	Δd_{S} for downward facing exhaust openings, in m		
$\Delta d_{\text{S}}^{\text{b}}$	Δd_{S} for horizontal exhaust openings, in m		
$\Delta d_{\text{S}}^{\text{c}}$	Δd_{S} for upward facing exhaust openings, in m		

Figure 2 — Position of the extraction points in the smoke layer with the assumed thickness of the smoke layer Δd_s

In the design process, the maximum volume flow that can be exhausted through a single extraction point, $\dot{V}_{i,\max}$, shall first be determined with the aid of the nomogram in [Figure 3](#). An example of how to proceed is given in [Figure 4](#).

The number, N , of extraction points is thus calculated as follows:

$N \geq$ volume flow to be exhausted/permitted volume flow per extraction point.

The minimum distance between the outer edges of two extraction points, S_{\min} , in metres is calculated as follows:

$$S_{\min} \geq 0,015 \sqrt{\dot{V}_i}$$

based on V_i in m^3/h .





Figure 3 — Nomogram for determining the maximum volume flow of smoke gases, $\dot{V}_{i,max}^*$, that can be exhausted through a single extraction point



Distance between the lower edge of the exhaust opening and the layer boundary $\Delta d_s = 1$ m.

Temperature of smoke layer $\theta_{RS} = 500$ $^{\circ}\text{C}$.

Resulting volume flow $\dot{V}_{i,\max}^* = 20\,000$ $\frac{\text{m}^3}{\text{h}}$.

Figure 4 — Example of how to use the nomogram shown in Figure 3

Centrally installed ventilators shall be set up outside the smoke reservoirs from which smoke is to be removed unless they are designed to be exposed to fire and are thus suitable for installation in the smoke reservoir itself (see Table 3).

The position of the smoke outlets at which smoke escapes from the building shall be selected in such a way that the smoke cannot be drawn back into the building at the air inlets.

This requirement is deemed to have been satisfied, without separate verification, if:

- the smoke outlet is located at least 2,5 m above the air inlet;
- for smoke outlets installed in walls, the horizontal distance between the smoke outlet and the air inlet is at least 8 m and the air inlet is not located above the smoke outlet;

- for smoke outlets installed in flat roofs without superstructures, the horizontal distance between the smoke outlet and the air inlet is at least 8 m and the air inlet is not located above the smoke outlet; or
- the smoke outlet and air inlet are located on different sides of the façade, the horizontal distance between the smoke outlet and the air inlet is at least 2,5 m and the air inlet is not located above the smoke outlet.

8 Energy supply for powered smoke exhaust ventilators

It shall be ensured that the power supply to ventilators and smoke control dampers is maintained and the control equipment continues to function properly in the event of a fire in accordance with building inspectorate requirements. The electrical cables for safety installations and equipment as required by the building regulations shall be designed or separated by building elements in such a way that the safety installations and equipment remain functional for a sufficient length of time in the event of a fire (functional integrity). Functional integrity shall also be ensured where safety installations and equipment can interact with other installations and equipment or parts thereof.

9 Controlling powered smoke exhaust ventilators

Powered smoke exhaust ventilators shall be switched on at an early state, e.g. via a fire alarm system with automatic detectors (generally activated by smoke), or immediately and manually by trained personnel that are in attendance around the clock. In addition, it shall be possible to activate powered smoke exhaust ventilators manually by push buttons.

Fire alarm systems shall be provided in the spaces in which powered smoke exhaust ventilators are to be installed.

For smoke control ducts with common shafts serving several storeys, the connections in each storey shall be fitted with adjustable smoke control dampers of the appropriate fire resistance class.

10 Marking

The manual initiation device shall be marked with the designation of the relevant smoke reservoir in accordance with ISO 21927-9.

Bibliography

- [1] *ISO 21927-1, Smoke and heat control systems — Part 1: Specification for smoke barriers*
- [2] *ISO 21927-7, Smoke and heat control systems — Part 7: Smoke ducts sections*
- [3] *ISO 21927-10, Smoke and heat control systems — Part 10: Specification for power output devices*
- [4] *EN 54-7, Fire detection and fire alarm systems — Part 7: Smoke detectors — Point detectors using scattered light, transmitted light or ionisation*